

• DO NOT SCALE THIS DRAWING. USE FIGURED DIMENSIONS ONLY. NO PART OF THIS DOCUMENT MAY BE REPRODUCED OR TRANSMITTED IN ANY FORM OR STORED IN ANY RETRIEVAL SYSTEM OF ANY NATURE WITHOUT THE WRITTEN PERMISSION OF O'CONNOR SUTTON CRONIN AS COPYRIGHT HOLDER EXCEPT AS AGREED FOR USE ON THE PROJECT FOR WHICH THE DOCUMENT WAS ORIGINALLY ISSUED.

Rev No. Date Revision Note	Drn by Chkd by		Head Office,		Client: ZOLBURY LIMITED
PLANNING DRAWING.			9 Prussia Street, Dublin 7. D07 KT57		Project: BLACKGLEN ROAD
NOT FOR CONSTRUCTION.		ENVIRONMENT QUALITY HEALTH & SAFETY 150 14001.2015 150 012015 OHSAS 1500012007			Title: WATERMAIN STANDARD DETAILS
ALL LEVELS GIVEN ARE		NSAI Certified NSAI Certified NSAI Certified	TEL +353 (0)1 8682000	OCSC	SHEET 1 OF 4
RELATIVE TO ORDENANCE DATUM.			122 1333 (0)1 8082000	O'CONNOR SUTTON CRONIN	
THIS DRAWING HAS BEEN ISSUED FOR INFORMATION		DSI. BIM Verified Design & Construction	e: contactus@ocsc.ie	Multidisciplinary Consulting Engineers	Code Originator Zone Level Type Role Number Status Revision
PURPOSES ONLY AND MUST NOT BE USED		Capital/Delivery PAS 1192-2	w: www.ocsc.ie		Z040 · OCSC · XX · XX · DR · C · 0560 S4 P03
FOR CONSTRUCTION UNDER ANY CIRCUMSTANCES			Dublin London Belfast	t Galway Cork	Date: 06/09/21Scale:SHWN @ A1 Drn by:RM Chkd by:AH Aprvd by:AH
					·

HYDRANT CHAMBERS SHALL BE COVERED WITH APPROVED HEAVY DUTY METAL COVERS TO IS 261 OR BS 5834 COVER AND FRAME SHALL BE SUITABLE FOR ROAD AND TRAFFIC CONDITIONS ALL HYDRANTS, SURFACE BOX FRAMES & COVERS SHALL COMPLY WITH THE RELEVANT PROVISIONS OF IS EN 14339, IS EN 1074-6 & BS 750. FIRE HYDRANTS SHALL BE TYPE 2. THE

HYDRANT CHAMBER TO BE CONSTRUCTED OF PRECAST CONCRETE UNITS OR HIGH DENSITY BLOCKWORK. ALTERNATIVELY PROPRIETARY PREFABRICATED CHAMBER UNITS MAY ALSO BE