


- FOR SETTING OUT REFER TO ARCHITECT'S DRAWINGS.
- THIS DRAWING TO BE READ IN CONJUNCTION WITH ALL OTHER ARCHITECTURAL AND ENGINEERING DRAWINGS AND ALL OTHER RELEVANT DRAWINGS AND SPECIFICATIONS.
- DO NOT SCALE THIS DRAWING. USE FIGURED DIMENSIONS ONLY.
- NO PART OF THIS DOCUMENT MAY BE REPRODUCED OR TRANSMITTED IN ANY FORM OR STORED IN ANY RETRIEVAL SYSTEM OF ANY NATURE WITHOUT THE WRITTEN PERMISSION OF O'CONNOR SUTTON CROWN AS COPYRIGHT HOLDER EXCEPT AS AGREED FOR USE ON THE PROJECT FOR WHICH THE DOCUMENT WAS ORIGINALLY ISSUED.

Rev No.	Date	Revision Note	Drn by	Chkd by
P01	29.04.22	SUITABLE FOR PLANNING ISSUE.	A.L.	G.M.
P02	22.08.22	SUITABLE FOR PLANNING ISSUE.	A.L.	G.M.

Rev No.	Date	Revision Note	Drn by	Chkd by



Head Office,
9 Prussia Street,
Dublin 7,
D07 KT57

TEL +353 (0)1 8682000
e: contactus@ocsc.ie
w: www.ocsc.ie

Dublin | London | Belfast | Galway | Cork | Birmingham



Client: ZOLBURY LTD.
Project: ADAMSTOWN STATION

Title: ELECTRICAL
SITE PUBLIC LIGHTING LAYOUT
SITE PLAN

Code [Originator] Zone | Level | Type | Role | Number | Status | Revision
K455-OCSC - XX - XX - SK - E - 0001 | S4 | P02

Date: 29.04.22 Scale: 1:500 @ A0 Drn by:A.L. Chkd by:G.M. Aprvd by:C.M.

- DRAWINGS NOTES:**
1. LIGHTING TO BE SUPPLIED VIA A SOLAR TIME CLOCK WITHIN EACH PUBLIC LIGHTING MINI PILLAR.
 2. A MAXIMUM OF 6No. LUMINAIRES PER CIRCUIT & 4No. CIRCUITS PER PUBLIC LIGHTING MINI PILLAR.
 3. ALL COLUMNS TO BE 6 METRES HIGH WITH A 1 METRE OUTREACH BRACKET & SETBACK 1 METRE FROM KERB.
 4. ALL COLUMNS TO BE HINGED & TO BE AT LEAST 1 METRE CLEAR OF ALL OVERHEAD HIGH VOLTAGE POWER LINES.
 5. ALL EQUIPMENT TO BE SUITABLY IP RATED FOR THE ENVIRONMENT THEY ARE BEING INSTALLED.
 6. FOR SCHEDULES OF EQUIPMENT SEE SPECIFICATION.
 7. THE COMPLETE INSTALLATION TO BE CO-ORDINATED WITH ALL OTHER SERVICES

LEGEND OF SYMBOLS:

- X1 20W 8M POLE MOUNTED LIGHT AVENUE
X2 15W 6M POLE MOUNTED LIGHT AVENUE
X3 52W 6M POLE MOUNTED LIGHT AVENUE

REF: 'X1' LUMINAIRE
THORN LIGHTING R212 S 12150 NR L730 CL2 BPS
STREET LIGHT 8m HIGH - 20W



REFER TO LUMINAIRE SCHEDULE

REF: 'X2' LUMINAIRE
THORN LIGHTING FW 12135-727 NR BPS HFX CL1 T60F ANT
AMENITY LIGHT 6m HIGH - 15W



REFER TO LUMINAIRE SCHEDULE

REF: 'X3' LUMINAIRE
THORN LIGHTING FW 121105-730 NR BPS HFX CL1 T60F ANT
STREET LIGHT 6m HIGH - 52W



REFER TO LUMINAIRE SCHEDULE